

# Certificate of Compliance

## Certificate

312413-410

## Issue Date

26 Jan 2024

## Expiration Date

19 Jan 2027



Ranee Valles  
Director and General Manager

UL Verification Services Inc.  
2211 Newmarket Parkway, ste 106  
Marietta, GA 30067 USA

UL Verification Services does hereby certify that an independent assessment has been conducted on behalf of:

## Sedus

for the following product:

## se:living side table

The product has been evaluated and meets the requirements for:

## GREENGUARD™

UL 2818 - 2022 Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

*Commercial furniture and furnishings are tested in accordance with ANSI/BIFMA M7.1-2011(R2016) and determined to comply with ANSI/BIFMA X7.1-2011(R2016) and ANSI/BIFMA e3-2019 Credit 7.6.1 in an Open Plan Office and Private Office environment.*



UL Solutions evaluated representative samples of the identified product, process or facility to the identified Standard or other requirements in accordance with the agreements and any applicable program service terms in place between UL Solutions and the Client (collectively "Agreement"). The Client is authorized to use the UL Mark for the identified Product, process or facility covered by this certificate, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement. This certificate is subject to modification, suspension and withdrawal by UL Solutions see SPOT.ul.com, to authenticate the certificate.

# Certificate of Compliance

## GREENGUARD Certification Criteria for Furniture and Mattresses

| Criteria                       | CAS Number | Maximum Allowable Predicted Concentration | Units             |
|--------------------------------|------------|-------------------------------------------|-------------------|
| TVOC <sub>(A)</sub>            | -          | 0.50                                      | mg/m <sup>3</sup> |
| Formaldehyde                   | 50-00-0    | 61.3 (50 ppb)                             | µg/m <sup>3</sup> |
| Total Aldehydes <sub>(B)</sub> | -          | 0.10                                      | ppm               |
| 4-Phenylcyclohexene            | 4994-16-5  | 6.5                                       | µg/m <sup>3</sup> |
| Individual VOCs <sub>(C)</sub> | -          | 1/10th TLV                                | -                 |

- (A) Defined to be the total response of measured VOCs falling within the C<sub>6</sub> – C<sub>16</sub> range, with responses calibrated to a toluene surrogate.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Allowable levels for chemicals not listed are derived from 1/10th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).